

ADDENDUM NUMBER 3

MARCIA COGGS HUMAN SERVICES CENTER
HVAC RENOVATIONS
Site #340, Bldg. #5600
1220 West Vliet Street
Milwaukee, WI

Project Number: S032-09434

Date of Addendum: December 1, 2011

This Addendum to the Contract Documents is issued to modify, explain or correct the original documents, dated November 7, 2011, and is hereby made part of the Contract Documents. Acknowledge receipt of this Addendum in the space provided on the Bid Form, or bid may be rejected.

DRAWINGS

- a. ADD the following note to drawings M3.0, M3.1 and P1.0.
"CEILING REMOVAL AND REPLACEMENT –
THE MECHANICAL CONTRACTOR SHALL PERFORM THIS WORK OR SUB-CONTRACT THE WORK TO A GENERAL CONTRACTOR. REMOVE ALL THE EXISTING CEILING TILES IN THE EXISTING FIRST FLOOR CORRIDOR TO PROVIDE ACCESS TO EXISTING PIPING AND PROVIDE NEW CHILLED WATER AND HOT WATER PIPING IN THE CORRIDOR. SAFELY STORE THE REMOVED CEILING TILES. REPLACE (RE-INSTALL) ALL THE EXISTING CEILING TILES WHEN WORK IS COMPLETE. IF AN EXISTING CEILING TILE IS BROKEN OR DAMAGED REPLACE WITH AN EXISTING CEILING TILE FROM THE BASE BID (THIRD FLOOR). THIS WORK SHALL BE CONSIDERED PART OF ALTERNATE A AND/OR B AS STATED IN THE DRAWING NOTES. THE NEW CHILLED AND HOT WATER PIPING BRANCHES FROM THE RISERS TO THE FIRST FLOOR CORRIDOR REQUIRES THE REMOVAL AND REPLACEMENT OF DRYWALL CEILINGS. MATCH EXISTING DRYWALL SYSTEM AND PAINT TO MATCH."

End of Addendum No. 3